

AWWA Free Water Audit Software: Reporting Worksheet

WAS v5.0

American Water Works Association
Copyright © 2014. All Rights Reserved

Click to access definition
Click to add a comment

Water Audit Report for: **City of Pittsburg**

Reporting Year: **2018** **7/2017 - 6/2018**

Please enter data in the white cells below. Where available, metered values should be used; if metered values are unavailable please estimate a value. Indicate your confidence in the accuracy of the input data by grading each component (n/a or 1-10) using the drop-down list to the left of the input cell. Hover the mouse over the cell to obtain a description of the grades

All volumes to be entered as: **MILLION GALLONS (US) PER YEAR**

To select the correct data grading for each input, determine the highest grade where the utility meets or exceeds all criteria for that grade and all grades below it.

WATER SUPPLIED

Volume from own sources: **5** 2,705.101 MG/Yr
Water imported: **n/a** 0.000 MG/Yr
Water exported: **n/a** 0.000 MG/Yr

WATER SUPPLIED: 2,705.101 MG/Yr

Master Meter and Supply Error Adjustments

Pcnt: **0** Value: **0** MG/Yr
Pcnt: **0** Value: **0** MG/Yr
Pcnt: **0** Value: **0** MG/Yr

Enter negative % or value for under-registration
Enter positive % or value for over-registration

AUTHORIZED CONSUMPTION

Billed metered: **7** 2,497.500 MG/Yr
Billed unmetered: **n/a** 0.000 MG/Yr
Unbilled metered: **n/a** 0.000 MG/Yr
Unbilled unmetered: **5** 6.763 MG/Yr

AUTHORIZED CONSUMPTION: 2,504.263 MG/Yr

Click here: **?** for help using option buttons below
Pcnt: **0** Value: **6.763** MG/Yr

Use buttons to select percentage of water supplied OR value

WATER LOSSES (Water Supplied - Authorized Consumption)

Apparent Losses

Unauthorized consumption: **5** 6.763 MG/Yr

Default option selected for unauthorized consumption - a grading of 5 is applied but not displayed

Customer metering inaccuracies: **3** 25.227 MG/Yr

Systematic data handling errors: **5** 6.244 MG/Yr

Default option selected for Systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: 38.234 MG/Yr

Pcnt: **0.25%** Value: **0** MG/Yr

1.00% **0.25%** MG/Yr

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: **?** 162.604 MG/Yr

WATER LOSSES: 200.838 MG/Yr

NON-REVENUE WATER

NON-REVENUE WATER: 207.601 MG/Yr

= Water Losses + Unbilled Metered + Unbilled Unmetered

SYSTEM DATA

Length of mains: **8** 253.0 miles
Number of active AND inactive service connections: **9** 18,886
Service connection density: **?** 75 conn./mile main

Are customer meters typically located at the curbstop or property line? **Yes**

Average length of customer service line: **?** (length of service line, beyond the property boundary, that is the responsibility of the utility)

Average length of customer service line has been set to zero and a data grading score of 10 has been applied

Average operating pressure: **2** 65.0 psi

COST DATA

Total annual cost of operating water system: **10** \$14,574,195 \$/Year
Customer retail unit cost (applied to Apparent Losses): **8** \$4.17 \$/100 cubic feet (ccf)
Variable production cost (applied to Real Losses): **5** \$2,545.00 \$/Million gallons ☐ Use Customer Retail Unit Cost to value real losses

WATER AUDIT DATA VALIDITY SCORE:

*** YOUR SCORE IS: 59 out of 100 ***

A weighted scale for the components of consumption and water loss is included in the calculation of the Water Audit Data Validity Score

PRIORITY AREAS FOR ATTENTION:

Based on the information provided, audit accuracy can be improved by addressing the following components:

1: Volume from own sources

2: Customer metering inaccuracies

3: Variable production cost (applied to Real Losses)